

## **Nepal Electricity Authority**

(An Undertaking of Nepal Government)

## Distribution and Consumer Services Directorate Nepal Distribution System Upgrade and Expansion Project (EIB)

Fax: 01-4153144 Phone: 01-4153145 Durbar Marg, Kathmandu

## Clarification-2

S.N.	Queries	Clarification
1.	Please confirm the type/material of insulators to be proposed in the tender i.e., either porcelain, polymer, or glass.	Tenderers shall propose Porcelain type pin insulators, disc insulators, shackle insulators and stay insulators.
2.	Please confirm what documents should be included in the outer envelope and the inner envelope.	As per the tender document, all documents except Price Schedule should be included in outer envelope. That is, only the Price Schedule (part of Volume IIIA and Volume IIIB) should be included in the inner envelope, and rest of the documents (including Technical Data Schedule of Volume IIIA and Volume IIIB) should be included in the outer envelope.



